#### Senseca Germany GmbH

Tenter Weg 2-8 | 42897 Remscheid | GERMANY Phone +49 2191 9672-0 | Fax +49 2191 9672-40 www.senseca.com | info@senseca.com | WEEE Reg. No. DE 93889386



### **Product Information**

# Flow switch LABO-RRH-S



- Uncomplicated monitoring of flow rates
- Metal housing with Hall sensor
- Working pressure up to 100 bar
- Long working life thanks to high quality ceramic axis and special plastic bearing
- Run-in and run-out sections are not necessary.
- Modular construction with various
- connection systems
  Plug-in and rotatable connections
- Optionally, non-return valve, filter, constant flow rate de
  - vice in the connections

#### Characteristics

The flow switch consists of a spinner which is rotated by the flowing medium. The rotor's rotational speed is proportional to the flow volume per unit time. The rotor is fitted with magnets. A Hall sensor records the rotational speed, which is proportional to the flow rate.

The LABO-RRH electronics make available an electronic switching output (push-pull) with adjustable characteristics

(minimum/maximum) and hysteresis, which responds when an adjustable limit is fallen short of or exceeded.

If desired, the switching value can be set to the currently existing flow using "teaching".

Models with analog or pulse output are also available.

Technical dat	ta					
Sensor	hall element					
Nominal width	DN 10 (LABC	)-RRH-010)				
	DN 25 (LABC	-				
Mechanical	female thread					
Connection	male thread	G <sup>3</sup> / <sub>8</sub> A. G1A				
	hose nozzle	Ø11, Ø30				
	(other thread	ed, crimped, and plug-in				
		connections with constant flow				
		r limiters available on request)				
Switching range		n ee table "Ranges"				
Maaauramant		neasured value				
Measurement accuracy						
Repeatability	±1 % of full s	cale value				
Pressure loss	max. 0.5 bar					
Compressive		H-025M: PN 40)				
strength		1 020				
Medium	060 °C, opt	tionally 0100 °C				
temperature		-				
Storage	-20+80 °C					
temperature						
Materials	Housing	CW614N nickelled or				
(wetted)	Deter	1.4305 DVD5 with means to				
	Rotor	PVDF with magnets, glued with epoxy resin				
	Bearing	Iglidur X				
	Axis	Ceramic Zr0 <sub>2</sub> -TZP				
	Seal	FKM				
Materials	Clamps	1.4301				
(non-wetted)	Electronic	CW614N nickelled				
(non netted)	housing					
Supply	1030 V DC					
voltage						
Power	< 1 W (for un	loaded outputs)				
consumption		• •				
Switching outp	ut transistor out	transistor output "push-pull"				
		(resistant to short circuits and polarity				
<b></b>	/	= 100 mA max.				
Display	yellow LED	l / Off - Alarm /				
	(On = Normal / Off = Alarm /					

#### Ranges

Weight

Electrical

connection

Conformity

Ingress protection IP 67

Metering range I/min (H <sub>2</sub> O)	Types	<b>Q</b> <sub>max</sub> I/min (H <sub>2</sub> O)
0.1 1.5	LABO-RRH-010020	1.8
0.2 10.0	LABO-RRH-010050	12.0
0.4 12.0	LABO-RRH-010070	14.4
2.0 30.0	LABO-RRH-025080	36.0
3.0 60.0	LABO-RRH-025120	72.0
4.0100.0	LABO-RRH-025160	120.0

LABO-RRH-010

LABO-RRH-025

CE

rapid flashing = Programming)

for round plug connector M12x1, 4-pole

approx. 0.6 kg

approx. 1.9 kg


#### Senseca Germany GmbH Tenter Weg 2-8 | 42897 Remscheid | GERMANY Phone +49 2191 9672-0 | Fax +49 2191 9672-40 www.senseca.com | info@senseca.com | WEEE Reg. No. DE 93889386



LABO-RRH-S

## Product Information

#### Wiring



Connection example: PNP NPN




Before the electrical installation, it must be ensured that the supply voltage corresponds to the data sheet.

#### It is recommended to use shielded wiring.

The push-pull output) can as desired be switched as a PNP or an NPN output.

#### Dimensions





#### Threaded connection

G	DN	Types	H/L	L1	в	С	Е	F	Х	SW
G <sup>3</sup> / <sub>8</sub>	10	RRH-010G	50	84	29	12.5	16.5	56	12	22
G <sup>3</sup> / <sub>8</sub> A		RRH-010A							14	
G 1	25	RRH-025G	70	110	53	23.0	27.5	51	18	38
G 1 A		RRH-025A		122						

NPT threads on request

#### Hose nozzle connection

D	DN	Types	H/L	L1	в	С	Е	F	X
Ø11	10	RRH-010T	50	96	29	12.5	16.5	56	21
Ø30	25	RRH-025T	70	176	53	23.0	27.5	51	45
Custom specific connectors on request									

#### Handling and operation

#### Installation

The flow switch is installed in the pipework with the aid of the rotatable adapter pieces. If necessary, the adapters can be removed from the body of the housing after the stainless steel clips have been removed from the housing. Before reinstalling, it should be ensured that both the adapter with the O-ring and the sealing surface in the body are clean and undamaged. The adapters should be fitted carefully in the housing (it is best to turn them), so that the O-ring is not damaged.

With this flow sensor, there is no need for run-in and run-out sections. However, it should be ensured that the flow sensor is at all times filled with medium. Any preferred installation position is possible, but the best possible venting position should be chosen (rotor axis horizontal, flow horizontal or from bottom to top).

Air bubbles affect the measurement results. For filling processes, the valve should be installed behind the sensor. A running up time of approx. 0.5 seconds and a running down time of approx. 3 seconds should be noted.

#### Note

The switching value can be programmed by the user via "teaching". If desired, programmability can be blocked by the manufacturer.

The ECI-1 device configurator with associated software is available as a convenient option for programming all parameters by PC, and for adjustment.

#### **Operation and programming**

The teaching process can be carried out by the user as follows:

- The flow rate to be set is applied to the device.
- Apply an impulse of at least 0.5 seconds and max. 2 seconds duration to pin 2 (e.g. via a bridge to the supply voltage or a pulse from the PLC), in order to accept the measured value.
- When the teaching is complete, pin 2 should be connected to 0 V, so as to prevent unintended programming.

The devices have a yellow LED which flashes during the programming pulse. During operation, the LED serves as an indicator of operating voltage (for analog output) or of switching status (for frequency or pulse output).

To avoid the need to transit to an undesired operating status for the purpose of teaching, the device can be provided ex-works with a teach-offset. The teach-offset point is added to the currently measured value before saving. The offset point can be positive or negative.

Example: The end of the metering range should be set to 80 %. However, only 60 % can be achieved without problem. In this case, the device would be ordered with a "teach-offset" of +20 %.. At a flow rate of 60 % in the process, teaching would then store a value of 80 %.

#### Senseca Germany GmbH

Tenter Weg 2-8 | 42897 Remscheid | GERMANY Phone +49 2191 9672-0 | Fax +49 2191 9672-40 www.senseca.com | info@senseca.com | WEEE Reg. No. DE 93889386

9.

E



. s

s

s

l/min

%

%


## **Product Information**

#### Ordering code

The basic device is ordered e.g. RRH-010xxx with electronics e.g. LABO-RRH-010xxx

1. 2. 3. 4. 5. 6. 7. 8.

RRH10 11 12 13 14 15 16



#### O=Option

1.	Nominal	width						
	010	DN 10		_				
	025	DN 25						
2.	Mechanie	cal connection						
	G	female thread						
	А	male thread	1					
	Т	hose nozzle	1					
3.	Connecti	on material	1					
	М	CW614N nickelled	1					
	К	1.4305						
4.	Housing	material	1					
	M CW614N							
	К	1.4305	1					
5.	Inwards	flow drilling	1					
	020	Ø 2.0		•				
	050	Ø 5.0		•				
	070	Ø 7.0		•				
	080	Ø 8.0	•					
	120	Ø12.0	•					
	160	Ø16.0	•					
6.	Seal mat							
	V	FKM	1					
	E Q	EPDM	1					
		NBR	1					
		Kemraz	1					
7.	Rotor	Toma	1					
<u> </u>	05	with 5 magnets						
		with 2 magnets	1					
8.	Rotor ma		1					
	V	PVDF	1					
9.	Connecti		1					
	E	electronics	1					
	_							
10.		inal width						
	010	DN 10		•				
	025	DN 25	•					
11.		g output (Limit switch)						
	S	push-pull (compatible with PNP and NPN)						
12.	Program							
	Р	programmable (teaching possible)						
L		cannot be programmed (no teaching)						
13.		g function						
<u> </u>	L H	minimum switch						
14.	H Switchin	maximum switch						
14.	O	standard						
	-	inverted						
15.		l connection						
	S	for round plug connector M12x1, 4-pole						
16.	Optional							
	-	100 °C version (with 300 mm cable)						

#### **Options for LABO**

Switching delay period (0.099.9 s)	
(from Normal to Alarm)	

Switch-back delay period (0.0...99.9 s) (from Alarm to Normal)

## **Power-On-Delay period** (0...99 s) (after connecting the supply, time during

which the switching output is not activated)

#### Switching output fixed at

#### Switching hysteresis

standard = 2 % of the metering range

#### Teach-offset

(in percent of the metering range) Standard = 0 %

Further options available on request.

#### Options

- Transparent cover DN 10
- Air or gas model

#### Accessories

- Cable/round plug connector (K04PU) see additional information "Accessories"
- Device configurator ECI-3