Senseca Germany GmbH

Tenter Weg 2-8 | 42897 Remscheid | GERMANY Phone +49 2191 9672-0 | Fax +49 2191 9672-40 www.senseca.com | info@senseca.com | WEEE Reg. No. DE 93889386



Technical data

Product Information

OMNI-P1

Pressure Transmitter / Switch OMNI-P1



- Analog output, two switching outputs
- Clear, easily legible, illuminated LCD display
- Modifiable units in the display
- Designed for industrial use

Characteristics

The OMNI-P1 pressure transmitter / switch is intended for the measurement of static and dynamic pressures in liquids and gases. It consists of a pressure cell as a sensor, and an integrated transformer

The sensor is an economical ceramic cell with a temperature compensated measuring bridge using thick film technology. It is protected from damage because of its non-flush construction, and is built extremely robustly.

The pressure present is shown in the display and output as an analog signal (0/4..20 mA or 0/2..10 V). In addition, if set limit values are fallen short of or exceeded, this can be signalled by means of two switching outputs and a red LED.

Because the complete upper part of the housing can be turned, it is possible to simply and infinitely adjust the display and the cable outlet.

By turning the programming ring to right or left, it is simple to modify the parameters (e.g. switching point, hysteresis...). To protect from unintended programming, it can be removed, turned through 180 $^{\circ}$, and replaced, or completely removed, thus acting as a key.



recillical data				
Sensor	ceramic cell with measuring bridge using thick film technology			
Process	male thread G ¹ / ₄ A, G ¹ / ₂ A			
connection	(optionally with female thread)			
Measurement ranges and	Range*		Over- pressure**	Burst pressure
pressure	bar	psi	bar	bar
resistance	0 1	0 14,5	5	6
	0 2	0 29,0	5	6
	0 5	0 72,5	7,5	15
	0 10	0 145	15	30
	0 20	0 290	30	60
	0 50	0 725	75	150
	0100	01450	150	250
		l measureme	nt ranges on	request
		ure values re		
	pressure	to the enviro	nment)	
	****		:44	_
	**The pressure transmitters may be loaded with the specified overpressure < 1 sec.			
Measurement		inal value;		
accuracy	plus 0.05 %/K at < 0 °C and > 60 °C			
Repeatability	±0.5 % of full scale value			
Dynamics	measurement cycle 32 ms, display cycle			
	0.5 sec.			
Working	-20+70 °C			
temperature	(with gooseneck max. 120 °C)			
Storage temperature	-20+80	°C		
Supply voltage	1830 V DC			
Power	< 1 W			
consumption				
Analog output	0/420 mA, 0/210 V via a 500 Ohm resistance after 0 V			
			oiver > 100 l	(Ohm)
Switching output	(impedance of the receiver > 100 kOhm) transistor output "push-pull"			
Switching output		t to short circ		ritv
	reversal)			,
		mA max.		
Hysteresis		le, for Min-sw		
	,	is above the lach, below the	,	nd for
Display				
Display	backlit graphical LCD-Display (transreflective), extended temperature			
	range -2	0+70°C, 32	x 16 pixels,	
		und illumination		
		hing LED sigi		
Electrical		eous messag I plug connec		
connection	ioi rouric	i piug connec	AUI WITZXI, O	-hoie
Ingress protection	IP 67			
Materials		steel 1.4571	. ceramic Al ₂	O ₃ . FKM
medium-contact			,	- 0,
Materials, non-		steel 1.4305		
medium-contact	mineral g	glass, POM (p	orogramming	
1	Comorius	m Cahalt (ma	anot)	

Samarium-Cobalt (magnet)

Senseca Germany GmbH


Tenter Weg 2-8 | 42897 Remscheid | GERMANY Phone +49 2191 9672-0 | Fax +49 2191 9672-40 www.senseca.com | info@senseca.com | WEEE Reg. No. DE 93889386



Product Information

OMNI-P1

Wiring




Before the electrical installation, it must be ensured that the supply voltage corresponds to the data sheet.

It is recommended to use shielded wiring.

The push-pull outputs can be set as a PNP or an NPN output, as desired.

Dimensions



Gooseneck option



A gooseneck (optional) between the electronics head and the primary sensor provides freedom in the orientation of the sensor. This option simultaneously provides thermal decoupling between the two units

Handling and operation

Installation

The pressure sensors are screwed into a nozzle or a T-piece in the pipework, using a suitable sealing material (e.g. Klingerit). The installation of the pressure sensor should result in no significant reduction of the cross-section of the pipework. When tightening the pressure sensor, use only the hexagonal spanner (SW27) specifically provided. Avoid installation locations with high pressure surges (see burst pressure).

In the high temperature model with flexible gooseneck, the pressure transducer can be operated up to a media temperature of 120 $^{\circ}\text{C}.$ For this model, it should also be ensured that the head with plug is not exposed to temperatures greater than 70 $^{\circ}\text{C}.$

Programming

The annular gap of the programming ring can be turned to positions 1 and 2. The following actions are possible:



Set to 1 = continue (STEP) Set to 2 = modify (EDIT)

Neutral position between 1 and 2

The ring can be removed to act as a key, or turned through 180 ° and replaced to create a programming protector.

Operation is by dialog with the display messages, which makes its use very simple.

Starting from the normal display (currently measured value with unit), if 1 (STEP) is repeatedly selected, then the display shows the following information in this order:

Display of the parameters, using position 1

- Switching value S1 (switching point 1 in the selected unit)
- Switching characteristic of S1
- (MIN = monitoring of minimum value, hysteresis higher than switching value,
- MAX = monitoring of maximum value, hysteresis less than switching value)
- Hysteresis 1 (hysteresis value of S1 in the set unit)
- Switching value S2
- Switching characteristic of S2
- Hysteresis 2
- Code:
 - After entering the code 111, further parameters can be defined:
- Filter (settling time of the display and output)
- Units (engineering units)
- Output: 0..20 mA or 4..20 mA
- 0/4 mA (value corresponding to 0/4 mA)
- 20 mA (value corresponding to 20 mA)

Edit, using position 2

If the currently visible parameter is to be modified:

- Turn the annular gap to position 2, so that a flashing cursor appears which displays the position which can be modified.
- By repeatedly turning to position 2, values are increased; by turning to position 1, the next digit is reached.
- Leave the parameter by turning to position 1 (until the cursor leaves the row); this accepts the modification
- If there is no action within 30 seconds, the device returns to the normal display range without accepting the modification.

The limit switches S1 and S2 can be used to monitor minimal or maximal.

With a minimum-switch, falling below the limit value causes a switchover to the alarm state. Return to the normal state occurs when the limit value plus the set hysteresis is once more exceeded.


Senseca Germany GmbH

Tenter Weg 2-8 | 42897 Remscheid | GERMANY Phone +49 2191 9672-0 | Fax +49 2191 9672-40 www.senseca.com | info@senseca.com | WEEE Reg. No. DE 93889386




Product Information

OMNI-P1



With a maximum-switch, exceeding the limit value causes a switchover to the alarm state. Return to the normal state occurs when the measured value once more falls below the limit value minus the set hysteresis.



The change to the alarm state is indicated by the integrated red LED and a cleartext in the display.

While in the normal state the switching outputs are at the level of the supply voltage; in the alarm state they are at 0 V, so that a wire break would also display as an alarm state at the signal receiver.

Simulation mode

To simplify commissioning, the sensor supports a simulation mode for the analog output. It is possible to create a programmable value in the range 0..21 mA at the output (without modifying the process variable). This allows the wiring run between the sensor and the downstream electronics to be tested during commissioning. This is mode is accessed by means of code 311.

Overload display

Overload of the switching output is detected, indicated on the display ("Check S1 / S2"), and the switching output is switched off.

Default setting

After setting the configuration parameters, they can be reset to factory values at any time, by means of code 989.

Ordering code

1. 2. 3. 4. 5. 6. 7. **OMNI-P1 - R K S**

O = Option

1.	Measurement range				
1.	001	0 1 bar			
	002	0 2 bar			
	002	0 5 bar			
	010	0 10 bar			
	020	0 20 bar			
	050	0 50 bar			
	100	0100 bar			
	200 0200 bar (on request)				
	400	0400 bar (on request)			
2.	Pressure type				
	R	relative pressure			
3.	Connection material				
<u> </u>	K	stainless steel			
4.	Mechanical connection				
	015	male thread G ¹ / ₂ A			
	008	D male thread G ¹ / ₄ A			
5.	Analog output				
	ı	Current output 0/420 mA			
	U	Voltage output 0/210 V (optional)			
6.	Electrical connection				
	S	for round plug connector M12x1, 5-pole			
7.	Optional				
	Н	model with gooseneck			
	0	O Tropic-model			
		oil-filled version for heavy use			
		or outdoor use			

Accessories

- Cable/round plug connector (K05..., KB05...) see additional information "Accessories"
- Device configurator ECI-3