GENERAL CHARACTERISTICS

This flooding detector allows an extremely precise control of the level of liquid. The system is based on measurement of the conductivity of the liquid to be detected and works with low potential and with alternating currents, in order to avoid the incrustation of the electrodes normally caused by the use of direct currents, which cause a galvanic action on materials.

The contact of the electrodes with the liquid under control determines the actuation of a relay inside the control unit, with which you can drive alarms or drain pumps.

- AISI 316 stainless steel electrodes.
- · Wall mounting.

 $(\epsilon$

Degree of protection IP65.



Code

110V

1-10MS

TECHNICAL DATA	Tab.1
I EURINICAL DATA	180.1

Description	Feature	s	Code
Power supply	24 / 230 Vac <u>+</u> 10%	50/60 Hz	24-230V
Power consumption	5 VA		
Power supply to probes	22 Vac		-
Electrodes	N. 2 x L=20 mm	AISI 316	0020
Sensitivity	10 –60 μS Facto	ory set 20 μS	10-60MS
Sensitivity adjustment	Internal trimmer		
Output relay	SPDT 250Vac 6A		
Operating temperature	-20 ÷ +50 °C		-
Housing	110 x 110 x 65 mm	ABS	
Degree of protection	IP65		IP65
Mounting	Wall mounting		
Electrical connection	10 poles terminal boa	rd	-
Cables input	PG7		

	W	IRI	ING
--	---	-----	-----


Terminal			
1	Input signal	Electrod	е
2			
3	Input signal	Electrod	е
4			
5		N.O.	
6	Output relay	Common	า
7		N.C.	
8		230	
9	Power supply	24	Vac
10		0	

DIMENSIONS - mm.

Options

110 Vac

Length L 1-10 μS



CONTROL AND ADJUSTMENT

Control:

Open the case, remove the leads from the terminals of the electrodes (terminals 1 and 3).

Short circuit terminals 1 and 3 of the terminal board, in these conditions, the relay must switch on and led has to light.

Sensitivity adjustment:

The unit is supplied with a factory setting of 20 µS.

Submerge the electrodes in the liquid to be tested, turn the trimmer on the PCB to obtain the switching of the relay.

NOMENCL	.ATURE				
SLA	10-60MS	0020	IP65	24-230V	
•					
	•				
		•			
			•		
				•	

We reserve the right to change the data without notice

BE#043/7-02/2012